

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010356.01-R4
DATE: 09/14/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage Millwork
CODE: 422-1
REVISION DATE: 05/04/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin Des Raymond Riviere-Du-Loup, Quebec G5R 4L9	Series "Wind Zone 3" Double Hung Weight & Chain Wood Prime Window Configuration: X/X Glazing: IG-4mm Tempered Glass/Laminate- 4mm Annealed Glass/0.090" DuPont Sentry Glass Plus Interlayer/4mm Annealed Glass Frame: W-1099mm(43.25") H-1937mm(76.25") Sash: W-914mm(36") H-981mm(38.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05	H-LC70 1099 x 1937 (43 x 76) Design Pressure: +70/-70 psf Wind Zone 3-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12960-2/NCTL-110-12960-1
Expiration Date: June 30, 2031

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-03/30/2023