

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010074.01-R4
DATE: 12/07/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage Millwork
CODE: 422-1
REVISION DATE: 05/04/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin Des Raymond Riviere-Du-Loup, Quebec G5R4L9	Series "Fixed Sash Hung XL/Wind Zone 3" Wood Prime Window Configuration: O Glazing: IG-4mm Annealed Glass/Laminate- 4mm Annealed Glass/0.090" Dupont Sentry Glass Plus Interlayer/4mm Annealed Glass Frame: W-1365mm(53.75") H-1604mm(63.13") Panel: W-1295mm(51") H-1575mm(62")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05	FW-R70 1365 x 1604 (54 x 63) Design Pressure: +70/-70 psf Wind Zone 3-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12303-1/110-12303-2
Expiration Date: August 31, 2031

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023