

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016853-R1
DATE: 11/20/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage
CODE: 422-1
REVISION DATE: 11/26/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin des Raymond Riviere-du-Loup, Quebec G5R 4L9	Series "XL-200" Wood Double Hung Window (w/ or w/o Aluminum Cladding) Configuration: X/X Glazing: IG-Ext. Laminate-4mm Annealed Glass/0.090" Sentry Glass Plus Interlayer by Kuraray/4mm Annealed Glass/Int. 4mm Annealed Glass Frame: W-965mm(38") H-1981mm(78") Panel: W-892mm(35.13") H-968mm(38.13") DLO: W-794mm(31.25") H-845mm(33.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E1886-19 ASTM E1996-20	Class R-PG70 965 x 1981 (38 x 78)-H Design Pressure: ± 3360 Pa (± 70 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: S8594.01-525-44/W-2177
Expiration Date: August 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023