

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015505.01-R1
DATE: 01/24/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage
CODE: 422-1
REVISION DATE: 10/27/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin des Raymond Riviere-du-Loup, Quebec G5R 4L9	Series "Clad Direct Set Impact Series (TF-100)" Aluminum Clad Wood Fixed Window Configuration: O Glazing: IG-Int.-4mm Annealed Glass/Ext.-Laminate- 4mm Annealed Glass/0.090" Sentry Glass Plus Interlayer/4mm Annealed Glass Frame: W-1829mm(72") H-1829mm(72") DLO: W-1737mm(68.38") H-1737mm(68.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a	Class CW-PG50 1829 x 1829 (72 x 72)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Wind Zone 3-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-24768-1/NCTL-110-24768-2
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023