

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010240.03-R4
DATE: 05/09/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage Millwork
CODE: 422-1
REVISION DATE: 05/04/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin Des Raymond Riviere-Du-Loup, Quebec G5R4L9	Series "Double French Outswing Door Wind Zone 3" Aluminum-Clad Wood Double French Door Configuration: XX Glazing: IG-4mm Annealed Glass/Laminate- 4mm Annealed Glass/0.090" Dupont Sentry Glass Plus Interlayer/4mm Annealed Glass Frame: W-1918mm(75.5") H-2502mm(98.5") Panel: W-908mm(35.75") H-2432mm(95.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-R60 1918 x 2502 (76 x 99)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12531-1/W-1485
Expiration Date: **December 31, 2031**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPOC-03/30/2023